



RESIDENTIAL RENTAL INSPECTION PROGRAM
 CITY OF GULF SHORES, ALABAMA
 251-968-1150
 EMAIL: jcampbell@gulfshoresal.gov

Owner Name: [REDACTED]
 Address: [REDACTED]
 Phone: [REDACTED]

Rental Property: Lyndi's Lous
 Address: 1308 West Beach Blvd
 Phone: [REDACTED]

General Notes:
 Rental Inspection Complete Date: 09/24/2026

CODE	INTERIOR INSEPECTION	STATUS	NOTES
704.2	SMOKE DETECTORS		
	Working Properly	Compliant	Installed in all required areas.
	Installed on every floor	Not Applicable	
	Installed in every sleeping room	Compliant	Installed in all sleeping rooms
	FIRE EXTINGUISHERS		
	Installed in kitchen	Compliant	Under kitchen sink, charged and compliant
	Installed on every floor	Not Applicable	
305.4 305.5	STAIRS		
	Handrails installed and secure	Not Applicable	
	Guardrails installed where required	Not Applicable	
	Stairway lighting	Not Applicable	
702.4	EMERGENCY RESCUE OPENINGS		
	Required windows are operable	Compliant	
	required doors are operable	Compliant	
	sleeping rooms provided w/ openings	Compliant	
605.1 604.3	ELECTRICAL		
	Electrical panels have covers	Compliant	
	No open wiring	Compliant	
CODE	EXTERIOR INSPECTIONS	STATUS	NOTES
304.1	BALCONIES AND DECKS		
	secured properly	Compliant	
	adequate support	Compliant	
	guardrails meet load requirements	Compliant	
303.1	SWIMMING POOLS		
	Proper gates / guards installed	Compliant	
	required alarms at exterior doors	Not Applicable	
304.12	STAIRS		
	Adequate support	Compliant	
	Guardrails properly secured	Compliant	Repair spindles on front stair landing. Photo attached
	Handrails installed	Compliant	
304.4	FOUNDATIONS		
	Adequate support for pile structures	Compliant	

304.3	Adequate connectors installed	Compliant
	911 ADDRESSING	
	4 Inch numbers on street side	Compliant
	4 inch numbers on beach side	Not Applicable

Rental Inspection Status: Approved with Comments